



# ADDENDUM

Addendum No. One

Page 1 of 1

Date: August 1, 2008

## Description and Location of Project:

**BARRIER-FREE RAMP INSTALLATION  
GOLDEN HORN ELEMENTARY SCHOOL  
WHITEHORSE, YUKON  
2008**

## To All Tenderers:

### 1. General:

- 1.1 This addendum shall be read in conjunction with the Drawings and Specifications.
- 1.2 Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.
- 1.3 No consideration shall be allowed for increases (extras) to the Contract Price due to the failure of the Contractor or Subcontractor being familiar with this addendum.
- 1.4 The Tenderer will insert in the Tender Form the numbers of the addenda received during the tendering period and taken into account in preparing their tender.

### 2. Scope of this Addendum:

#### 2.1 MEMBRANE ROOFING

##### .1 WARRANTY

As this is a small exterior project, no warranty is required for the membrane roof. Note that the lack of this requirement does not infringe on the quality of the installation. All materials and installation shall be of best quality for the purpose intended.

##### .2 MEMBRANE MATERIAL

Minimum 2-ply (base sheet and sanded top sheet) membrane roofing material is appropriate for this application.

### 3. Attachments:

N/A