



ADDENDUM

Addendum No. 2
Page 1 of 1
Date: July 24, 2008

Description and Location of Project:

STAGE REFLOORING
YUKON ARTS CENTRE - BLDG. 1313
WHITEHORSE, YUKON
2008

To All Tenderers:

1. General:

- 1.1 This addendum shall be read in conjunction with the Drawings and Specifications.
- 1.2 Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.
- 1.3 No consideration shall be allowed for increases (extras) to the Contract Price due to the failure of the Contractor or Subcontractor being familiar with this addendum.
- 1.4 The Tenderer will insert in the Tender Form the numbers of the addenda received during the tendering period and taken into account in preparing their tender.

2. Scope of this Addendum:

- 2.1 Tender Closing date has been extended to Wednesday July 30, 2008.
- 2.2 After removal of existing masonite flooring, inspect existing plywood.
- 2.3 If existing plywood is determined by owner to be in good condition, install 2.0mm, jute backing Corkment Underlayment by Forbo or approved alternate.
- 2.4 Corkment to be installed as per manufacturers requirements.
- 2.5 Use ¼" black schluter around floor plates and as required.

3. Attachments: n/a

Laura Vanderkley/
Project Officer

July 24, 2008
Date

(867) 456-6816
Phone No.